

Assessment for: Recompence Shore Campgrounds, ID ME0007020  
Location: Freeport, Maine  
Date: May 8, 2003

### **Summary of the Data used in our Assessment**

Well type: Bedrock Well  
Well identification number: 7020101  
Well description: Dr Well 440'  
Overburden thickness (feet): 287  
Positive bacteria test result(s): No  
Nitrate test result(s) greater than 5 ppm: Yes  
Septic system(s) within 300 feet of the well: Yes  
Animal feedlots/manure piles(s) within 300 feet of the well: No

### **Risk Based on Well Type and Site Geology**

*Ranking:*

Well type: Bedrock Well  
Overburden thickness (feet): 287

*Existing risk of contamination  
based on well type & site geology:*

**Low risk**

### **Existing Risk of Acute Contamination**

*Ranking:*

Positive coliform test(s): No  
Nitrate test(s) greater than 5 ppm: Yes  
Septic system(s) within 300 feet of the well: Yes  
Animal feedlot(s)/manure pile(s) within 300 feet of the well: No

*Existing risk of acute contamination:*

**High risk**

### **Future Risk for Acute Contamination**

*Ranking:*

Status of land control: The source proprietor owns or controls all the land within 300 feet of this water supply source.

*Future risk of acute contamination:*

**Low risk**