

Assessment for: Lie-niels en Toolworks, ID ME0094718
Location: Warren, Maine
Date: April 15, 2003

Summary of the Data used in our Assessment

Public Water Supply Information

Well type: Bedrock well
Well identification number: 94718101
Well description: 200' Bedrock Well Unknown Date/yield
Overburden thickness (feet): Unknown
Wellhead protection radius around the well: 300
Reported distance of land control around the well: 300

Risk Based on Well Type and Site Geology

Well type: Bedrock well
Well identification number: 94718101
Overburden thickness (feet): Unknown

*Existing risk of contamination
based on well type & site geology:*

Moderate risk

Existing Risk of Acute Contamination

Well identification number: 94718101
Positive coliform test: No
Nitrate test greater than 5 ppm: No
Septic system within 300 feet of the well: Yes

Existing risk of acute contamination:

Moderate risk

Future Risk of Acute Contamination

Well identification number: 94718101
No legal land control or control status is unknown or
legal control is less than a 150-foot radius around the well: No
Legal control of at least a 150-foot radius of property around the well: Yes
Legal control of at least a 300-foot radius of property around the well: Yes

Future risk of acute contamination:

Low risk

Existing Risk of Chronic Contamination

Well identification number: 94718101
Detection of Chronic Chemical Contaminant: Yes
Name(s) of Chronic Chemical Contaminant(s) Detected: Cyanide

Total No. Potential Sources of Contamination within WHPA: None reported
Distance to nearest "Significant Potential Source of Contamination": No distance data reported (feet)
Name of nearest "Significant Potential Source of Contamination": No potential sources of chemical contaminants reported or no distance data reported.

Existing risk of chronic contamination:

Moderate risk

Future Risk of Chronic Contamination - Land Ownership / Control

Legal control of Entire Wellhead Protection Area: Yes
Legal control of 2500 Phase II/V Waiver Radius: No
Future risk of chronic contamination:

Moderate risk