

Assessment for: Holly & Dougs Country Diner; ID ME0095000

Location: Norridgewock, Maine

Date: September 29, 2011

Summary of the Data used in our Assessment

Well type: Bedrock well

Well identification number: 95000101

Well description: Bedrock well, 520 ft deep

Overburden thickness (feet): not known

Positive bacteria test result(s): No

Nitrate test result(s) greater than 5 ppm: No

Septic system(s) within 300 feet of the well: Yes, 165 ft; have variance with State

Animal feedlots/manure piles(s) within 300 feet of the well: No

Risk Based on Well Type and Site Geology

Ranking:

Well type: Bedrock well

Overburden thickness (feet): not known

*Existing risk of contamination
based on well type & site geology:*

Moderate risk

Existing Risk of Acute Contamination

Ranking:

Positive coliform test(s): No

Nitrate test(s) greater than 5 ppm: No

Septic system(s) within 300 feet of the well: Yes; 165 ft; Have variance with the State

Animal feedlot(s)/manure pile(s) within 300 feet of the well: No

Existing risk of acute contamination:

Low risk

Future Risk for Acute Contamination

Ranking:

Status of land control: The owner owns and/or controls 25 ft of the well head protection radius of 300 ft.

Future risk of acute contamination:

High risk