

Assessment for: Msu 76 Sedgwick Elem School, ID ME0094407

Location: Sedgwick, Maine

Date: April 15, 2003

Summary of the Data used in our Assessment

Public Water Supply Information

Well type: Bedrock well

Well identification number: 94407101

Well description: Dr Well#1

Overburden thickness (feet): 260

Wellhead protection radius around the well: 300

Reported distance of land control around the well: 30

Risk Based on Well Type and Site Geology

Well type: Bedrock well

Well identification number: 94407101

Overburden thickness (feet): 260

*Existing risk of contamination
based on well type & site geology:*

Low risk

Existing Risk of Acute Contamination

Well identification number: 94407101

Positive coliform test: No

Nitrate test greater than 5 ppm: No

Septic system within 300 feet of the well: Yes

Existing risk of acute contamination:

Moderate risk

Future Risk of Acute Contamination

Well identification number: 94407101

No legal land control or control status is unknown or

legal control is less than a 150-foot radius around the well: Yes

Legal control of at least a 150-foot radius of property around the well: No

Legal control of at least a 300-foot radius of property around the well: No

Future risk of acute contamination:

High risk

Existing Risk of Chronic Contamination

Well identification number: 94407101

Detection of Chronic Chemical Contaminant: Yes

Name(s) of Chronic Chemical Contaminant(s) Detected: Chromium

Total No. Potential Sources of Contamination within WHPA: 2

Distance to nearest "Significant Potential Source of Contamination": 500 (feet)

Name of nearest "Significant Potential Source of Contamination": Underground oil storage tank

Existing risk of chronic contamination:

Moderate risk

Future Risk of Chronic Contamination - Land Ownership / Control

Legal control of Entire Wellhead Protection Area: No

Legal control of 2500 Phase II/V Waiver Radius: No

Future risk of chronic contamination:

High risk