



STATE OF MAINE  
DEPARTMENT OF ENVIRONMENTAL PROTECTION



PAUL R. LEPAGE  
GOVERNOR

PATRICIA W. AHO  
COMMISSIONER

**Southern Maine Health Care  
York County  
Biddeford, Maine  
A-006-71-P-R/M (SM)**

**Departmental  
Findings of Fact and Order  
Air Emission License  
Renewal/Amendment**

**FINDINGS OF FACT**

After review of the air emissions license renewal application, staff investigation reports and other documents in the applicant's file in the Bureau of Air Quality, pursuant to 38 Maine Revised Statutes Annotated (M.R.S.A.), §344 and §590, the Maine Department of Environmental Protection (Department) finds the following facts:

**I. REGISTRATION**

**A. Introduction**

Southern Maine Health Care at the Biddeford Campus (SMHC-Biddeford) has applied to renew their Air Emission License permitting the operation of emission sources associated with their healthcare facility.

SMHC-Biddeford has requested a minor revision to their license in order to reflect a name change to the facility. The facility was previously known as The Webber Hospital Associate doing business as (dba) Southern Maine Medical Center. The name change does not reflect any changes in ownership of the facility.

The equipment addressed in this license is located at 1 Medical Center Drive in Biddeford, Maine.

**B. Emission Equipment**

The following equipment is addressed in this air emission license:

**Boilers**

<b><u>Equipment</u></b>	<b><u>Maximum Capacity</u></b>	<b><u>Maximum Firing Rate</u></b>	<b><u>Fuel Type, % sulfur</u></b>	<b><u>Date of Manuf.</u></b>	<b><u>Stack #</u></b>
Boiler #1	12.6 MMBtu/hr	90 gal/hr	Distillate, 0.5% S	1978	1
		12,353 scf/hr	Natural Gas		
Boiler #2	12.6 MMBtu/hr	90 gal/hr	Distillate, 0.5% S	1978	1
		12,353 scf/hr	Natural Gas		
Boiler #3	6.3 MMBtu/hr	45 gal/hr	Distillate, 0.5% S	1990	1
		6,177 scf/hr	Natural Gas		

AUGUSTA  
17 STATE HOUSE STATION  
AUGUSTA, MAINE 04333-0017  
(207) 287-7688 FAX: (207) 287-7826  
RAY BLDG., HOSPITAL ST.

BANGOR  
106 HOGAN ROAD, SUITE 6  
BANGOR, MAINE 04401  
(207) 941-4570 FAX: (207) 941-4584

PORTLAND  
312 CANCO ROAD  
PORTLAND, MAINE 04103  
(207) 822-6300 FAX: (207) 822-6303

PRESQUE ISLE  
1235 CENTRAL DRIVE, SKYWAY PARK  
PRESQUE ISLE, MAINE 04769  
(207) 764-0477 FAX: (207) 760-3143

**Generators**

<u>Equipment</u>	<u>Maximum Capacity</u>	<u>Firing Rate (gal/hr)</u>	<u>Fuel Type, % sulfur</u>	<u>Date of Manuf.</u>
Generator #1	7.4 MMBtu/hr	54.0	Distillate, 0.0015% S	1978
Generator #2	7.4 MMBtu/hr	54.0	Distillate, 0.0015% S	1990
Generator #3	5.12 MMBtu/hr	37.4	Distillate, 0.0015% S	2007

C. Application Classification

The application for SMHC-Biddeford does not include the licensing of increased emissions or the installation of new or modified equipment. Therefore, the license is considered to be a renewal and minor revision and has been processed as such through *Major and Minor Source Air Emission License Regulations*, 06-096 Code of Maine Rules (CMR) 115 (as amended). With the annual distillate fuel limit on the boilers and the operating hours restriction on the emergency generators, the facility is licensed below the major source thresholds for both criteria pollutants and hazardous air pollutants (HAP), and is therefore considered a synthetic minor and an area source of HAP.

**II. BEST PRACTICAL TREATMENT (BPT)**

A. Introduction

In order to receive a license, the applicant must control emissions from each unit to a level considered by the Department to represent Best Practical Treatment (BPT), as defined in *Definitions Regulation*, 06-096 CMR 100 (as amended). Separate control requirement categories exist for new and existing equipment.

BPT for existing emissions equipment means that method which controls or reduces emissions to the lowest possible level considering:

- the existing state of technology;
- the effectiveness of available alternatives for reducing emissions from the source being considered; and
- the economic feasibility for the type of establishment involved.

B. Boilers #1, #2, and #3

Boilers #1, #2, and #3 are rated with maximum capacities of 12.6 MMBtu/hr, 12.6 MMBtu/hr, and 6.3 MMBtu/hr, respectively, and each has the capability to fire both distillate fuel and natural gas. Boilers #1 and #2 were installed in 1978 and Boiler #3 was installed in 1990. All three boilers, as well as Generators #1 and #2, exhaust to a combined stack, designated Stack #1.

Due to the year of manufacture of Boilers #1 and #2 and the size of Boiler #3, the boilers are not subject to the New Source Performance Standards (NSPS) 40 CFR Part 60,

Subpart Dc, *Standards of Performance for Small Industrial-Commercial-Institutional Steam Generating Units*, for units greater than 10 MMBtu/hr manufactured after June 9, 1989.

1. BPT Findings

The BPT emission limits for Boilers #1, #2, and #3 were based on the following:

Distillate Fuel

- PM/PM<sub>10</sub> – 0.10 lb/MMBtu based on 06-096 CMR 115, BPT
- SO<sub>2</sub> – Based on firing ASTM D396 compliant #2 fuel oil (0.5% sulfur by weight)
- NO<sub>x</sub> – 20 lb/1000 gal based on AP-42, Table 1.3-1, dated 5/10
- CO – 5 lb/1000 gal based on AP-42, Table 1.3-1, dated 5/10
- VOC – 0.34 lb/1000 gal based on AP-42, Table 1.3-3, dated 5/10
- Opacity – 06-096 CMR 101

Natural Gas

- PM/PM<sub>10</sub> – 0.05 lb/MMBtu based on 06-096 CMR 115, BPT
- SO<sub>2</sub> – 0.6 lb/MMscf based on AP-42, Table 1.4-2, dated 7/98
- NO<sub>x</sub> – 100 lb/MMscf based on AP-42, Table 1.4-1, dated 7/98
- CO – 84 lb/MMscf based on AP-42, Table 1.4-1, dated 7/98
- VOC – 5.5 lb/MMscf based on AP-42, Table 1.4-2, dated 7/98
- Opacity – 06-096 CMR 101

The BPT emission limits for Boilers #1, #2, and #3 are the following:

<u>Units</u>	<u>Fuel Type</u>	<u>Pollutant</u>	<u>lb/MMBtu</u>	<u>Origin and Authority</u>
Boiler #1	Distillate fuel	PM	0.10	06-096 CMR 115, BPT
	Natural gas	PM	0.05	06-096 CMR 115, BPT
Boiler #2	Distillate fuel	PM	0.10	06-096 CMR 115, BPT
	Natural gas	PM	0.05	06-096 CMR 115, BPT
Boiler #3	Distillate fuel	PM	0.10	06-096 CMR 115, BPT
	Natural gas	PM	0.05	06-096 CMR 115, BPT

<u>Units</u>	<u>Fuel Type</u>	<u>PM (lb/hr)</u>	<u>PM<sub>10</sub> (lb/hr)</u>	<u>SO<sub>2</sub> (lb/hr)</u>	<u>NO<sub>x</sub> (lb/hr)</u>	<u>CO (lb/hr)</u>	<u>VOC (lb/hr)</u>
Boiler #1	Distillate fuel	1.26	1.26	6.35	1.80	0.45	0.03
	Natural gas	0.63	0.63	0.01	1.24	1.04	0.07
Boiler #2	Distillate fuel	1.26	1.26	6.35	1.80	0.45	0.03
	Natural gas	0.63	0.63	0.01	1.24	1.04	0.07
Boiler #3	Distillate fuel	0.63	0.63	3.17	0.90	0.23	0.02
	Natural gas	0.32	0.32	0.01	0.62	0.52	0.03

Visible emissions from the common stack serving the boilers and Generators #1 and #2 shall not exceed 30% opacity on a 6-minute block average, except for no more than three (3) six (6) minute block averages in a 3-hour period.

SMHC-Biddeford shall be limited to a combined 300,000 gallons/year of distillate fuel in Boilers #1, #2, and #3 based on a 12-month rolling total. There is no limit on the amount of natural gas that can be fired in the boilers.

Prior to July 1, 2016, or by the date otherwise stated in 38 MRSA §603-A(2)(A)(3), any distillate fuel fired in Boilers #1, #2, and #3 shall be ASTM D396 compliant #2 fuel oil (maximum sulfur content of 0.5% by weight). Per 38 MRSA §603-A(2)(A)(3), beginning July 1, 2016, or on the date specified in the statute, the facility shall fire distillate fuel with a maximum sulfur content limit of 0.005% by weight (50 ppm), and beginning January 1, 2018, or on the date specified in the statute, the facility shall fire distillate fuel with a maximum sulfur content limit of 0.0015% by weight (15 ppm). The specific dates contained in this paragraph reflect the current dates in the statute as of the effective date of this license; however, if the statute is revised, the facility shall comply with the revised dates upon promulgation of the statute revision.

2. Periodic Monitoring

Periodic monitoring for the boilers shall include recordkeeping to document fuel use both on a monthly and 12-month rolling total basis. Documentation shall include the quantity and type of fuel used and sulfur content of the fuel, if applicable.

3. 40 CFR Part 63 Subpart JJJJJ

Boilers #1, #2, and #3 are subject to the *National Emission Standards for Hazardous Air Pollutants for Industrial, Commercial, and Institutional Boilers Area Sources* (40 CFR Part 63 Subpart JJJJJ). The units are considered existing oil boilers.

Gas-fired boilers are exempt from 40 CFR Part 63, Subpart JJJJJ. However, boilers which fire fuel oil are not. A “gas-fired boiler” is defined as any boiler that burns gaseous fuels not combined with any solid fuels and burns liquid fuel only during periods of gas curtailment, gas supply interruption, startups, or periodic testing on liquid fuel. Periodic testing of liquid fuel shall not exceed a combined total of 48 hours during any calendar year.[40 CFR Part 63.11237]

Any boiler designed to burn fuels besides gaseous fuels prior to June 4, 2010 will be considered an existing boiler under this rule. A boiler which currently fires gaseous fuels, but converts back to firing another fuel (such as distillate fuel) in the future would become subject as an existing boiler at the time it is converted back to oil.

A summary of the currently applicable federal 40 CFR Part 63 Subpart JJJJJ requirements is listed below. At this time, the Department has not taken delegation of this area source MACT (Maximum Achievable Control Technology) rule promulgated by EPA, however SMHC-Biddeford is still subject to the requirements. Notification forms and additional rule information can be found on the following website: <http://www.epa.gov/ttn/atw/boiler/boilerpg.html>.

a. Compliance Dates, Notifications, and Work Practice Requirements

i. Initial Notification of Compliance

An Initial Notification was submitted to the EPA in September of 2011 prior to the January 20, 2014 deadline. [40 CFR Part 63.11225(a)(2)]

ii. Boiler Tune-Up Program

(a) A boiler tune-up program was implemented and included the initial tune-up of applicable boilers prior to the March 21, 2014 deadline. [40 CFR Part 63.11223]

1. Each subsequent tune-up shall be conducted at a frequency specified by the rule and based on the size, age, and operations of the boiler. See chart below:

<b>Boiler Category</b>	<b>Tune-Up Frequency</b>
New or Existing Oil, Biomass and Coal fired boilers that are not designated as "Boilers with less frequent tune up requirements" listed below	Every 2 years
<b><i>New and Existing Oil, Biomass, and Coal fired Boilers with less frequent tune up requirements</i></b>	
Boiler with oxygen trim system which maintains an optimum air-to-fuel ratio that would otherwise be subject to a biennial tune up	Every 5 years

[40 CFR Part 63.11223(a) and Table 2]

2. The tune-up compliance report shall be maintained onsite and, if requested, submitted to EPA. The report shall contain the concentration of CO in the effluent stream (ppmv) and oxygen in volume percent, measured at high fire or typical operating load, before and after the boiler tune-up, a description of any corrective actions taken as part of the tune-up of the boiler, and the types and amounts of fuels used over the 12 months prior to the tune-up of the boiler. [40 CFR Part 63.11223(b)(6)] The compliance report shall also include the company name and address; a compliance statement signed by a

responsible official certifying truth, accuracy, and completeness; and a description of any deviations and corrective actions. [40 CFR Part 63.11225(b)]

(b) The boiler tune-up program, conducted to demonstrate continuous compliance, shall be performed as specified below:

1. As applicable, inspect the burner, and clean or replace any component of the burner as necessary. Delay of the burner inspection until the next scheduled shutdown is permitted; not to exceed 36 months from the previous inspection for boilers greater than 5 MMBtu/hr or 72 months from the previous inspection for boilers with oxygen trim systems. [40 CFR Part 63.11223(b)(1)]
2. Inspect the flame pattern, as applicable, and adjust the burner as necessary to optimize the flame pattern, consistent with the manufacturer's specifications. [40 CFR Part 63.11223(b)(2)]
3. Inspect the system controlling the air-to-fuel ratio, as applicable, and ensure it is correctly calibrated and functioning properly. Delay of the inspection until the next scheduled shutdown is permitted; not to exceed 36 months from the previous inspection for boilers greater than 5 MMBtu/hr or 72 months from the previous inspection for boilers with oxygen trim systems. [40 CFR Part 63.11223(b)(3)]
4. Optimize total emissions of CO, consistent with manufacturer's specifications. [40 CFR Part 63.11223(b)(4)]
5. Measure the concentration in the effluent stream of CO in parts per million by volume (ppmv), and oxygen in volume percent, before and after adjustments are made (measurements may be either on a dry or wet basis, as long as it is the same basis before and after the adjustments are made). Measurements may be taken using a portable CO analyzer. [40 CFR Part 63.11223(b)(5)]
6. If a unit is not operating on the required date for a tune-up, the tune-up must be conducted within 30 days of start-up. [40 CFR Part 63.11223(b)(7)]

(c) After conducting the initial boiler tune-up, a Notification of Compliance Status was submitted to the EPA in July of 2012 prior to the July 19, 2014 deadline. [40 CFR Part 63.11225(a)(4) and 40 CFR Part 63.11214(b)]

iii. Energy Assessment

Boilers #1 and #2 are subject to the energy assessment requirement as follows:

(a) A one-time energy assessment was performed on March 17, 2014 by a qualified energy assessor for the facility, including the applicable boilers, prior to the March 21, 2014 deadline. [40 CFR Part 63.11196(a)(3)]

(b) The energy assessment was required to include a visual inspection of the boiler system; an evaluation of operating characteristics of the affected boiler systems, specifications of energy use systems, operating and maintenance procedures, and unusual operating constraints; an inventory of major energy use systems consuming energy from affected boiler(s) and which are under control of the boiler owner or operator; a review of available architectural and engineering plans, facility operation and maintenance procedures and logs, and fuel usage; a list of major energy conservation measures that are within the facility's control; a list of the energy savings potential of the energy conservation measures identified; and a comprehensive report detailing the ways to improve efficiency, the cost of specific improvements, benefits, and the time frame for recouping those investments. [40 CFR Part 63, Table 2(4)]

(c) A Notification of Compliance Status for the energy assessment was submitted to EPA through their electronic reporting system on November 14, 2014. [40 CFR Part 63.11225(a)(4) and 40 CFR Part 63.11214(c)]

b. Recordkeeping

Records shall be maintained consistent with the requirements of 40 CFR Part 63 Subpart JJJJJ including the following [40 CFR Part 63.11225(c)]: copies of notifications and reports with supporting compliance documentation; identification of each boiler, the date of tune-up, procedures followed for tune-up, and the manufacturer's specifications to which the boiler was tuned; documentation of fuel type(s) used monthly by each boiler; the occurrence and duration of each malfunction of the boiler; and actions taken during periods of malfunction to minimize emissions and actions taken to restore the malfunctioning boiler to its usual manner of operation. Records shall be in a form suitable and readily available for expeditious review.

C. Generators #1 and #2

Generators #1 and #2 are emergency generators that are each rated at 7.4 MMBtu/hr. The generators fire distillate fuel and were manufactured in 1978 and 1990, respectively. Generators #1 and #2 exhaust through Stack #1 in combination with Boilers #1, #2, and #3.

1. BPT Findings

The BPT emission limits for Generators #1 and #2 are based on the following:

Distillate Fuel

- PM/PM<sub>10</sub> - 0.12 lb/MMBtu from 06-096 CMR 103
- SO<sub>2</sub> - Combustion of distillate fuel with a maximum sulfur content not to exceed 15 ppm (0.0015% sulfur by weight)
- NO<sub>x</sub> - 3.2 lb/MMBtu based on AP-42, Table 3.4-1, dated 10/96
- CO - 0.85 lb/MMBtu based on AP-42, Table 3.4-1, dated 10/96
- VOC - 0.09 lb/MMBtu based on AP-42, Table 3.4-1, dated 10/96
- Opacity - 06-096 CMR 101

The BPT emission limits for Generators #1 and #2 are the following:

Units	Pollutant	lb/MMBtu	Origin and Authority
Generator #1	PM	0.12	06-096 CMR 103, Section (2)(B)(1)(a)
Generator #2	PM	0.12	06-096 CMR 103, Section (2)(B)(1)(a)

Units	PM (lb/hr)	PM <sub>10</sub> (lb/hr)	SO <sub>2</sub> (lb/hr)	NO <sub>x</sub> (lb/hr)	CO (lb/hr)	VOC (lb/hr)
Generator #1	0.89	0.89	0.01	23.68	6.29	0.67
Generator #2	0.89	0.89	0.01	23.68	6.29	0.67

Visible emissions from Stack #1 (serving the boilers and Generators #1 and #2) shall not exceed 30% opacity on a 6-minute block average, except for no more than three (3) six (6) minute block averages in a 3-hour period.

Generators #1 and #2 shall each be limited to 100 hours of operation per calendar year, excluding operating hours during emergency situations. There is no limit on emergency operation. Generators #1 and #2 shall each be equipped with a non-resettable hour-meter to record operating time. To demonstrate compliance with the operating hours limit, SMHC-Biddeford shall keep records of the total hours of operation and the hours of emergency operation for each unit.

Generators #1 and #2 are only to be operated for maintenance purposes and for situations arising from sudden and reasonably unforeseeable events beyond the control of the source. Generators #1 and #2 are not to be used for prime power when reliable offsite power is available; nor to operate or to be contractually obligated to be available for more than 15 hours per calendar year in a demand response program, during a period of deviation from standard voltage or frequency, or supplying power during a non-emergency situation as part of a financial arrangement with another entity.

2. 40 CFR Part 63, Subpart ZZZZ

The federal regulation 40 CFR Part 63, Subpart ZZZZ, *National Emission Standards for Hazardous Air Pollutants (NESHAP) for Stationary Reciprocating Internal*

*Combustion Engines* is not applicable to Generators #1 and #2 listed above. The units are considered existing, emergency stationary reciprocating internal combustion engines at an area HAP source. However, they are considered exempt from the requirements of Subpart ZZZZ since they are categorized as institutional emergency engines and they do not operate or are not contractually obligated to be available for more than 15 hours per calendar year in a demand response program, during a period of deviation from standard voltage or frequency, or supplying power during a non-emergency situation as part of a financial arrangement with another entity as specified in §63.6640(f)(4)(ii).

Operation of the emergency generators such that each exceeds 15 hours per calendar year in a demand response program, during a period of deviation from standard voltage or frequency, or supplying power during a non-emergency situation as part of a financial arrangement with another entity as specified in §63.6640(f)(4)(ii), would cause the generator(s) to be subject to 40 CFR Part 63, Subpart ZZZZ, and require compliance with all applicable requirements.

D. Generator #3

Generator #3 is an emergency generator rated at 5.12 MMBtu/hr that was manufactured in 2007. The generator fires distillate fuel.

1. BPT Findings

The BPT emission limits for Generator #3 are based on the following:

Distillate Fuel

- PM/PM<sub>10</sub> - 0.12 g/hp-hr based on the manufacturer's not-to-exceed data
- SO<sub>2</sub> - Combustion of distillate fuel with a maximum sulfur content not to exceed 15 ppm (0.0015% sulfur by weight)
- NO<sub>x</sub> - 6.99 g/hp-hr based on the manufacturer's not-to-exceed data
- CO - 2.28 g/hp-hr based on the manufacturer's not-to-exceed data
- VOC - 0.11 g/hp-hr based on the manufacturer's not-to-exceed data
- Opacity - 06-096 CMR 101

The BPT emission limits for Generator #3 are the following:

<u>Unit</u>	<u>Pollutant</u>	<u>g/hp-hr</u>	<u>Origin and Authority</u>
Generator #3	PM	0.12	Manufacturer's Not-To-Exceed Data and 06-096 CMR 115, BPT

<u>Unit</u>	<u>PM (lb/hr)</u>	<u>PM<sub>10</sub> (lb/hr)</u>	<u>SO<sub>2</sub> (lb/hr)</u>	<u>NO<sub>x</sub> (lb/hr)</u>	<u>CO (lb/hr)</u>	<u>VOC (lb/hr)</u>
Generator #3	0.20	0.20	0.01	12.01	3.91	0.19

Visible emissions from Generator #3 shall not exceed 20% opacity on a 6-minute block average, except for no more than two (2) six (6) minute block averages in a 3-hour period.

2. 40 CFR Part 60, Subpart III

The federal regulation 40 CFR Part 60, Subpart III, *Standards of Performance for Stationary Compression Ignition Internal Combustion Engines (CI ICE)* is applicable to the emergency generator (Generator #3) listed above since the unit was ordered after July 11, 2005 and manufactured after April 1, 2006. By meeting the requirements of Subpart III, the unit also meets the requirements found in the *National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines*, 40 CFR Part 63, Subpart ZZZZ.

a. Emergency Definition:

Emergency stationary ICE means any stationary reciprocating internal combustion engine that meets all of the following criteria:

- (1) The stationary ICE is operated to provide electrical power or mechanical work during an emergency situation. Examples include stationary ICE used to produce power for critical networks or equipment (including power supplied to portions of a facility) when electric power from the local utility (or the normal power source, if the facility runs on its own power production) is interrupted, or stationary ICE used to pump water in the case of fire or flood, etc. There is no time limit on the use of emergency stationary ICE in emergency situations.
- (2) Paragraph (1) above notwithstanding, the emergency stationary ICE may be operated for any combination of the purposes specified below for a maximum of 100 hours per calendar year:
  - (i) Maintenance checks and readiness testing, provided that the tests are recommended by federal, state or local government, the manufacturer, the vendor, the regional transmission organization or equivalent balancing authority and transmission operator, or the insurance company associated with the engine. The owner or operator may petition the Administrator for approval of additional hours to be used for maintenance checks and readiness testing, but a petition is not required if the owner or operator maintains records indicating that federal, state, or local standards require maintenance and testing of emergency ICE beyond 100 hours per calendar year.
  - (ii) Emergency demand response for periods in which the Reliability Coordinator under the North American Electric Reliability Corporation (NERC) Reliability Standard EOP-002-3, Capacity and Energy

Emergencies (incorporated by reference, see §63.14), or other authorized entity as determined by the Reliability Coordinator, has declared an Energy Emergency Alert Level 2 as defined in the NERC Reliability Standard EOP-002-3.

(iii) Periods where there is a deviation of voltage or frequency of 5 percent or greater below standard voltage or frequency.

(3) Paragraphs (1) and (2) above notwithstanding, emergency stationary ICE may be operated for up to 50 hours per calendar year in non-emergency situations. These 50 hours are counted as part of the 100 hours per calendar year for maintenance checks and readiness testing, emergency demand response, and periods of voltage deviation or low frequency, as provided in paragraph (2) above.

The 50 hours per calendar year for non-emergency situations cannot be used for peak shaving, non-emergency demand response, or to generate income for a facility by providing power to an electric grid or otherwise supply power as part of a financial arrangement with another entity, except if the following conditions are met:

- (i) The engine is dispatched by the local balancing authority or local transmission and distribution system operator.
- (ii) The dispatch is intended to mitigate local transmission and/or distribution limitations so as to avert potential voltage collapse or line overloads that could lead to the interruption of power supply in a local area or region.
- (iii) The dispatch follows reliability, emergency operation or similar protocols that follow specific NERC, regional, state, public utility commission or local standards or guidelines.
- (iv) The power is provided only to the facility itself or to support the local transmission and distribution system.
- (v) The owner or operator identifies and records the entity that dispatches the engine and the specific NERC, regional, state, public utility commission or local standards or guidelines that are being followed for dispatching the engine. The local balancing authority or local transmission and distribution system operator may keep these records on behalf of the engine owner or operator.

[40 CFR §60.4211(f) and §60.4219]

b. 40 CFR Part 60, Subpart III Requirements:

(1) Manufacturer Certification Requirement

Generator #3 shall be certified by the manufacturer as meeting the emission standards for new nonroad compression ignition engines found in 40 CFR §60.4202. [40 CFR §60.4205(b)]

(2) Ultra-Low Sulfur Fuel Requirement

The fuel fired in Generator #3 shall not exceed 15 ppm sulfur (0.0015% sulfur), except that any existing fuel purchased (or otherwise obtained) prior to October 1, 2010, may be used until depleted. [40 CFR §60.4207(b)]

(3) Non-Resettable Hour Meter Requirement

A non-resettable hour meter shall be installed and operated on Generator #3. [40 CFR §60.4209(a)]

(4) Operation and Maintenance Requirements

Generator #3 shall be operated and maintained according to the manufacturer's emission-related written instructions or procedures developed by SMHC-Biddeford that are approved by the engine manufacturer. SMHC-Biddeford may only change those emission-related settings that are permitted by the manufacturer. [40 CFR §60.4211(a)]

(5) Annual Time Limit for Maintenance and Testing

Generator #3 shall be limited to 100 hours/year for maintenance checks and readiness testing, emergency demand response, and periods of voltage or frequency deviation from standards. Up to 50 hours/year of the 100 hours/year may be used in non-emergency situations (this does not include peak shaving, non-emergency demand response, or to generate income for a facility by providing power to an electric grid or otherwise supply power as part of a financial arrangement with another entity unless the conditions in §60.4211(f)(3)(i) are met). [40 CFR §60.4211(f)]

(6) Initial Notification Requirement

No initial notification is required for emergency engines. [40 CFR §60.4214(b)]

(7) Recordkeeping

SMHC-Biddeford shall keep records that include maintenance conducted on Generator #3 and the hours of operation of the engine recorded through the non-resettable hour meter. Documentation shall include the hours spent for emergency operation, including what classified the operation as emergency and how many hours spent for non-emergency. If Generator #3 is operated during a period of demand response or deviation from standard voltage or frequency, or to supply power during a non-emergency situation as part of a financial arrangement with another entity as specified in §60.4211(f)(3)(i), SMHC-Biddeford shall keep records of the notification of the emergency situation, and the date, start time, and end time of generator operation for these purposes. [40 CFR §60.4214(b)]

(8) Annual Reporting Requirements for Demand Response Availability Over 15 Hours Per Year (for generators greater than 100 brake hp)

If Generator #3 operates or is contractually obligated to be available for more than 15 hours per calendar year in a demand response program, during a period of deviation from standard voltage or frequency, or supplying power during a non-emergency situation as part of a financial arrangement with another entity as specified in §60.4211(f)(3)(i), SMHC-Biddeford shall submit an annual report containing the information in §60.4214(d)(1)(i) through (vii). The first annual report must cover the calendar year 2015 and must be submitted no later than March 31, 2016. Subsequent annual reports for each calendar year must be submitted no later than March 31 of the following calendar year. The annual report must be submitted electronically using the Compliance and Emissions Data Reporting Interface (CEDRI) that is accessed through EPA's Central Data Exchange (CDX) ([www.epa.gov/cdx](http://www.epa.gov/cdx)). However, if the reporting form is not available in CEDRI at the time that the report is due, the written report must be submitted to the following address:

Director, Office of Ecosystem Protection  
U.S. Environmental Protection Agency  
5 Post Office Square, Suite 100  
Boston, MA 02109-3912

[40 CFR §60.4214(d)]

E. Annual Emissions

1. Total Annual Emissions

Due to the fact that emissions are dependent on the fuel being fired, and SMHC-Biddeford wishes to retain licensed capability to fire distillate fuel and natural gas in the boilers, the facility shall be restricted to the maximum annual emissions from the fuel, or combination of fuels, which yields the highest tons per year quantity for each pollutant. The tons per year of pollutants from distillate fuel were based on the annual limit of 300,000 gallons and the tons per year of pollutants from natural gas were based on maximum operation for 8,760 hours/year. Due to these limitations, the worst case-scenario to yield the highest emissions for PM, PM<sub>10</sub>, SO<sub>2</sub>, and NO<sub>x</sub> emissions occur when firing distillate fuel for the entirety of the fuel cap in either Boiler #1 or Boiler #2 and the remainder of the year firing natural gas in the applicable boilers, and Boiler #3 firing natural gas continuously for 8,760 hours/year. The highest emissions for CO and VOC occur when firing natural gas continuously for the whole year in Boilers #1, #2, and #3. The ton per year limits for the emergency generators (Generators #1, #2, and #3) were each calculated based on an operation of 100 hours/year.

SMHC-Biddeford shall be restricted to the following annual emissions, based on a calendar year:

**Total Licensed Annual Emissions for the Facility**  
**Tons/year**  
 (used to calculate the annual license fee)

	<b>PM</b>	<b>PM<sub>10</sub></b>	<b>SO<sub>2</sub></b>	<b>NO<sub>x</sub></b>	<b>CO</b>	<b>VOC</b>
Boilers #1, #2, #3	8.0	8.0	10.7	14.5	11.4	0.8
Generator #1	0.04	0.04	0.01	1.2	0.3	0.03
Generator #2	0.04	0.04	0.01	1.2	0.3	0.03
Generator #3	0.01	0.01	0.01	0.6	0.2	0.01
<b>Total TPY</b>	<b>8.1</b>	<b>8.1</b>	<b>10.7</b>	<b>17.5</b>	<b>12.2</b>	<b>0.9</b>

2. Greenhouse Gases

Greenhouse gases are considered regulated pollutants as of January 2, 2011, through 'Tailoring' revisions made to EPA's *Approval and Promulgation of Implementation Plans*, 40 CFR Part 52, Subpart A, §52.21 Prevention of Significant Deterioration of Air Quality rule. Greenhouse gases, as defined in 06-096 CMR 100 (as amended), are the aggregate group of the following gases: Carbon dioxide, nitrous oxide, methane, hydrofluorocarbons, perfluorocarbons, and sulfur hexafluoride. For licensing purposes, greenhouse gases (GHG) are calculated and reported as carbon dioxide equivalents (CO<sub>2</sub>e).

Based on the facility's fuel use limit(s), the worst case emission factors from AP-42, IPCC (Intergovernmental Panel on Climate Change), and *Mandatory Greenhouse Gas Reporting*, 40 CFR Part 98, and the global warming potentials contained in 40 CFR Part 98, SMHC-Biddeford is below the major source threshold of 100,000 tons of CO<sub>2</sub>e per year. Therefore, no additional licensing requirements are needed to address GHG emissions at this time.

**III. AMBIENT AIR QUALITY ANALYSIS**

The level of ambient air quality impact modeling required for a minor source shall be determined by the Department on a case-by case basis. In accordance with 06-096 CMR 115, an ambient air quality impact analysis is not required for a minor source if the total licensed annual emissions of any pollutant released do not exceed the following levels and there are no extenuating circumstances:

<b>Pollutant</b>	<b>Tons/Year</b>
PM <sub>10</sub>	25
SO <sub>2</sub>	50
NO <sub>x</sub>	50
CO	250

The total licensed annual emissions for the facility are below the emission levels contained in the table above and there are no extenuating circumstances; therefore, an ambient air quality impact analysis is not required as part of this license.

### ORDER

Based on the above Findings and subject to conditions listed below, the Department concludes that the emissions from this source:

- will receive Best Practical Treatment,
- will not violate applicable emission standards, and
- will not violate applicable ambient air quality standards in conjunction with emissions from other sources.

The Department hereby grants Air Emission License A-006-71-P-R/M subject to the following conditions.

Severability. The invalidity or unenforceability of any provision, or part thereof, of this License shall not affect the remainder of the provision or any other provisions. This License shall be construed and enforced in all respects as if such invalid or unenforceable provision or part thereof had been omitted.

### STANDARD CONDITIONS

- (1) Employees and authorized representatives of the Department shall be allowed access to the licensee's premises during business hours, or any time during which any emissions units are in operation, and at such other times as the Department deems necessary for the purpose of performing tests, collecting samples, conducting inspections, or examining and copying records relating to emissions (38 M.R.S.A. §347-C).
- (2) The licensee shall acquire a new or amended air emission license prior to commencing construction of a modification, unless specifically provided for in Chapter 115. [06-096 CMR 115]
- (3) Approval to construct shall become invalid if the source has not commenced construction within eighteen (18) months after receipt of such approval or if construction is discontinued for a period of eighteen (18) months or more. The Department may extend this time period upon a satisfactory showing that an extension is justified, but may condition such extension upon a review of either the control technology analysis or the ambient air quality standards analysis, or both. [06-096 CMR 115]
- (4) The licensee shall establish and maintain a continuing program of best management practices for suppression of fugitive particulate matter during any period of construction,

reconstruction, or operation which may result in fugitive dust, and shall submit a description of the program to the Department upon request. [06-096 CMR 115]

- (5) The licensee shall pay the annual air emission license fee to the Department, calculated pursuant to Title 38 M.R.S.A. §353-A. [06-096 CMR 115]
- (6) The license does not convey any property rights of any sort, or any exclusive privilege. [06-096 CMR 115]
- (7) The licensee shall maintain and operate all emission units and air pollution systems required by the air emission license in a manner consistent with good air pollution control practice for minimizing emissions. [06-096 CMR 115]
- (8) The licensee shall maintain sufficient records to accurately document compliance with emission standards and license conditions and shall maintain such records for a minimum of six (6) years. The records shall be submitted to the Department upon written request. [06-096 CMR 115]
- (9) The licensee shall comply with all terms and conditions of the air emission license. The filing of an appeal by the licensee, the notification of planned changes or anticipated noncompliance by the licensee, or the filing of an application by the licensee for a renewal of a license or amendment shall not stay any condition of the license. [06-096 CMR 115]
- (10) The licensee may not use as a defense in an enforcement action that the disruption, cessation, or reduction of licensed operations would have been necessary in order to maintain compliance with the conditions of the air emission license. [06-096 CMR 115]
- (11) In accordance with the Department's air emission compliance test protocol and 40 CFR Part 60 or other method approved or required by the Department, the licensee shall:
  - A. perform stack testing to demonstrate compliance with the applicable emission standards under circumstances representative of the facility's normal process and operating conditions:
    1. within sixty (60) calendar days of receipt of a notification to test from the Department or EPA, if visible emissions, equipment operating parameters, staff inspection, air monitoring or other cause indicate to the Department that equipment may be operating out of compliance with emission standards or license conditions; or
    2. pursuant to any other requirement of this license to perform stack testing.
  - B. install or make provisions to install test ports that meet the criteria of 40 CFR Part 60, Appendix A, and test platforms, if necessary, and other accommodations necessary to allow emission testing; and

- C. submit a written report to the Department within thirty (30) days from date of test completion.  
[06-096 CMR 115]
- (12) If the results of a stack test performed under circumstances representative of the facility's normal process and operating conditions indicate emissions in excess of the applicable standards, then:
- A. within thirty (30) days following receipt of such test results, the licensee shall re-test the non-complying emission source under circumstances representative of the facility's normal process and operating conditions and in accordance with the Department's air emission compliance test protocol and 40 CFR Part 60 or other method approved or required by the Department; and
  - B. the days of violation shall be presumed to include the date of stack test and each and every day of operation thereafter until compliance is demonstrated under normal and representative process and operating conditions, except to the extent that the facility can prove to the satisfaction of the Department that there were intervening days during which no violation occurred or that the violation was not continuing in nature; and
  - C. the licensee may, upon the approval of the Department following the successful demonstration of compliance at alternative load conditions, operate under such alternative load conditions on an interim basis prior to a demonstration of compliance under normal and representative process and operating conditions.  
[06-096 CMR 115]
- (13) Notwithstanding any other provisions in the State Implementation Plan approved by the EPA or Section 114(a) of the CAA, any credible evidence may be used for the purpose of establishing whether a person has violated or is in violation of any statute, regulation, or Part 70 license requirement. [06-096 CMR 115]
- (14) The licensee shall maintain records of malfunctions, failures, downtime, and any other similar change in operation of air pollution control systems or the emissions unit itself that would affect emissions and that is not consistent with the terms and conditions of the air emission license. The licensee shall notify the Department within two (2) days or the next state working day, whichever is later, of such occasions where such changes result in an increase of emissions. The licensee shall report all excess emissions in the units of the applicable emission limitation. [06-096 CMR 115]
- (15) Upon written request from the Department, the licensee shall establish and maintain such records, make such reports, install, use and maintain such monitoring equipment, sample such emissions (in accordance with such methods, at such locations, at such intervals, and in such a manner as the Department shall prescribe), and provide other information as the Department may reasonably require to determine the licensee's compliance status. [06-096 CMR 115]

**SPECIFIC CONDITIONS**

**(16) Boilers #1, #2, and #3**

**A. Fuel**

1. Boilers #1, #2, and #3 are licensed to fire distillate fuel and natural gas.
2. Total distillate fuel use for Boilers #1, #2, and #3 shall not exceed a combined 300,000 gallons/year, based on a calendar year. [06-096 CMR 115, BPT]
3. Prior to July 1, 2016 or the date specified in 38 MRSA §603-A(2)(A)(3), the distillate fuel fired in the boilers shall be ASTM D396 compliant #2 fuel oil (max. sulfur content of 0.5% by weight). [06-096 CMR 115, BPT]
4. Beginning July 1, 2016 or on the date specified in 38 MRSA §603-A(2)(A)(3), the facility shall fire distillate fuel with a maximum sulfur content limit of 0.005% by weight (50 ppm). [38 MRSA §603-A(2)(A)(3)]
5. Beginning January 1, 2018 or on the date specified in 38 MRSA §603-A(2)(A)(3), the facility shall fire distillate fuel with a maximum sulfur content limit of 0.0015% by weight (15 ppm). [38 MRSA §603-A(2)(A)(3)]
6. Compliance shall be demonstrated by fuel records from the supplier showing the quantity, type, and the percent sulfur of the fuel delivered (if applicable). Records of annual fuel use shall be kept on a monthly and calendar year basis. [06-096 CMR 115, BPT]

**B. Emissions shall not exceed the following:**

Units	Fuel Type	Pollutant	lb/MMBtu	Origin and Authority
Boiler #1	Distillate Fuel	PM	0.10	06-096 CMR 115, BPT
	Natural Gas	PM	0.05	06-096 CMR 115, BPT
Boiler #2	Distillate Fuel	PM	0.10	06-096 CMR 115, BPT
	Natural Gas	PM	0.05	06-096 CMR 115, BPT
Boiler #3	Distillate Fuel	PM	0.10	06-096 CMR 115, BPT
	Natural Gas	PM	0.05	06-096 CMR 115, BPT

**C. Emissions shall not exceed the following [06-096 CMR 115, BPT]:**

Units	Fuel Type	PM (lb/hr)	PM <sub>10</sub> (lb/hr)	SO <sub>2</sub> (lb/hr)	NO <sub>x</sub> (lb/hr)	CO (lb/hr)	VOC (lb/hr)
Boiler #1	Distillate Fuel	1.26	1.26	6.35	1.80	0.45	0.03
	Natural Gas	0.63	0.63	0.01	1.24	1.04	0.07
Boiler #2	Distillate Fuel	1.26	1.26	6.35	1.80	0.45	0.03
	Natural Gas	0.63	0.63	0.01	1.24	1.04	0.07
Boiler #3	Distillate Fuel	0.63	0.63	3.17	0.90	0.23	0.02
	Natural Gas	0.32	0.32	0.01	0.62	0.52	0.03

- D. Visible emissions from the common stack serving the boilers and Generators #1 and #2 (Stack #1) shall not exceed 30% opacity on a 6-minute block average, except for no more than three (3) six (6) minute block averages in a 3-hour period. [06-096 CMR 101]
- E. Boiler MACT (40 CFR Part 63, Subpart JJJJJ) Requirements for Boilers #1, #2, and #3 [incorporated under 06-096 CMR 115, BPT]
1. The facility shall conduct performance tune-ups to demonstrate continuous compliance. [40 CFR Part 63.11223(a)]
    - (a) Each tune-up shall be conducted at a frequency specified by the rule and based on the size, age, and operations of the boiler. See chart below:

<b>Boiler Category</b>	<b>Tune-Up Frequency</b>
New or Existing Oil, Biomass and Coal fired boilers that are not designated as "Boilers with less frequent tune up requirements" listed below	Every 2 years
<b><i>New and Existing Oil, Biomass, and Coal fired Boilers with less frequent tune up requirements</i></b>	
Boiler with oxygen trim system which maintains an optimum air-to-fuel ratio that would otherwise be subject to a biennial tune up	Every 5 years

[40 CFR Part 63.11223(a) and Table 2]

- (b) The tune-up compliance report shall be maintained onsite and, if requested, submitted to EPA. The report shall contain the concentration of CO in the effluent stream (ppmv) and oxygen in volume percent, measured at high fire or typical operating load, before and after the boiler tune-up, a description of any corrective actions taken as part of the tune-up of the boiler, and the types and amounts of fuels used over the 12 months prior to the tune-up of the boiler. [40 CFR Part 63.11223(b)(6)] The compliance report shall also include the company name and address; a compliance statement signed by a responsible official certifying truth, accuracy, and completeness; and a description of any deviations and corrective actions. [40 CFR Part 63.11225(b)]
2. The boiler tune-up program, conducted to demonstrate continuous compliance, shall be performed as specified below:

- (a) As applicable, inspect the burner, and clean or replace any component of the burner as necessary. Delay of the burner inspection until the next scheduled shutdown is permitted; not to exceed 36 months from the previous inspection for boilers greater than 5 MMBtu/hr or 72 months from the previous inspection for boilers with oxygen trim systems. [40 CFR Part 63.11223(b)(1)]
  - (b) Inspect the flame pattern, as applicable, and adjust the burner as necessary to optimize the flame pattern, consistent with the manufacturer's specifications. [40 CFR Part 63.11223(b)(2)]
  - (c) Inspect the system controlling the air-to-fuel ratio, as applicable, and ensure it is correctly calibrated and functioning properly. Delay of the inspection until the next scheduled shutdown is permitted; not to exceed 36 months from the previous inspection for boilers greater than 5 MMBtu/hr or 72 months from the previous inspection for boilers with oxygen trim systems. [40 CFR Part 63.11223(b)(3)]
  - (d) Optimize total emissions of CO, consistent with manufacturer's specifications. [40 CFR Part 63.11223(b)(4)]
  - (e) Measure the concentration in the effluent stream of CO in parts per million by volume (ppmv), and oxygen in volume percent, before and after adjustments are made (measurements may be either on a dry or wet basis, as long as it is the same basis before and after the adjustments are made). Measurements may be taken using a portable CO analyzer. [40 CFR Part 63.11223(b)(5)]
  - (f) If a unit is not operating on the required date for a tune-up, the tune-up must be conducted within 30 days of start-up. [40 CFR Part 63.11223(b)(7)]
3. Records shall be maintained consistent with the requirements of 40 CFR Part 63 Subpart JJJJJ including the following [40 CFR Part 63.11225(c)]: copies of notifications and reports with supporting compliance documentation; identification of each boiler, the date of tune-up, procedures followed for tune-up, and the manufacturer's specifications to which the boiler was tuned; documentation of fuel type(s) used monthly by each boiler; the occurrence and duration of each malfunction of the boiler; and actions taken during periods of malfunction to minimize emissions and actions taken to restore the malfunctioning boiler to its usual manner of operation. Records shall be in a form suitable and readily available for expeditious review.

(17) **Generators #1 and #2**

- A. Generators #1 and #2 shall each be limited to 100 hours of operation per calendar year, excluding operating hours during emergency situations. [06-096 CMR 115]
- B. SMHC-Biddeford shall keep records that include maintenance conducted on Generators #1 and #2 and the hours of operation of each engine recorded through the

non-resettable hour meter. Documentation shall include the hours spent for emergency operation, including what classified the operation as emergency and how many hours spent for non-emergency. [06-096 CMR 115, BACT]

C. The fuel sulfur content for Generators #1 and #2 shall each be limited to 0.0015% sulfur by weight. Compliance shall be demonstrated by fuel records from the supplier documenting the type of fuel delivered and the sulfur content of the fuel. [06-096 CMR 115, BPT]

D. Emissions shall not exceed the following:

Units	Pollutant	lb/MMBtu	Origin and Authority
Generator #1	PM	0.12	06-096 CMR 103, Section (2)(B)(1)(a)
Generator #2	PM	0.12	06-096 CMR 103, Section (2)(B)(1)(a)

E. Emissions shall not exceed the following [06-096 CMR 115, BPT]:

Units	PM (lb/hr)	PM <sub>10</sub> (lb/hr)	SO <sub>2</sub> (lb/hr)	NO <sub>x</sub> (lb/hr)	CO (lb/hr)	VOC (lb/hr)
Generator #1	0.89	0.89	0.01	23.68	6.29	0.67
Generator #2	0.89	0.89	0.01	23.68	6.29	0.67

F. Visible emissions from the common stack serving the boilers and Generators #1 and #2 (Stack #1) shall not exceed 30% opacity on a 6-minute block average, except for no more than three (3) six (6) minute block averages in a 3-hour period. [06-096 CMR 101]

G. Generators #1 and #2 are only to be operated for maintenance purposes and for situations arising from sudden and reasonably unforeseeable events beyond the control of the source. Generators #1 and #2 are not to be used for prime power when reliable offsite power is available; nor to operate or to be contractually obligated to be available for more than 15 hours per calendar year in a demand response program, during a period of deviation from standard voltage or frequency, or supplying power during a non-emergency situation as part of a financial arrangement with another entity.

H. If Generators #1 and #2 are operated for 15 hours per calendar year or less during a period of demand response or deviation from standard voltage or frequency, or to supply power during a non-emergency situation as part of a financial arrangement with another entity, SMHC-Biddeford shall keep records of the notification of the emergency situation, and the date, start time, and end time of generator operation for these purposes. [06-096 CMR 115, BACT]

(18) **Generator #3**

- A. Generator #3 shall be limited to 100 hours of operation per calendar year, excluding operating hours during emergency situations. [06-096 CMR 115]
- B. Emissions shall not exceed the following:

Unit	Pollutant	g/hp-hr	Origin and Authority
Generator #3	PM	0.12	Manufacturer's Not-To-Exceed Data and 06-096 CMR 115, BPT

- C. Emissions shall not exceed the following [06-096 CMR 115, BPT]:

Unit	PM (lb/hr)	PM <sub>10</sub> (lb/hr)	SO <sub>2</sub> (lb/hr)	NO <sub>x</sub> (lb/hr)	CO (lb/hr)	VOC (lb/hr)
Generator #3	0.20	0.20	0.01	12.01	3.91	0.19

- D. Visible emissions from the Generator #3 shall not exceed 20% opacity on a six (6) minute block average, except for no more than two (2) six (6) minute block averages in a continuous 3-hour period. [06-096 CMR 101]
- E. Generator #3 shall meet the applicable requirements of 40 CFR Part 60, Subpart IIII, including the following:

1. **Manufacturer Certification**

Generator #3 shall be certified by the manufacturer as meeting the emission standards for new nonroad compression ignition engines found in §60.4202. [40 CFR §60.4205(b)]

2. **Ultra-Low Sulfur Fuel**

The fuel fired in Generator #3 shall not exceed 15 ppm sulfur (0.0015% sulfur), except that any existing fuel purchased (or otherwise obtained) prior to October 1, 2010, may be used until depleted. Compliance with the fuel sulfur content limit shall be based on fuel records from the supplier documenting the type of fuel delivered and the sulfur content of the fuel. [40 CFR §60.4207(b) and 06-096 CMR 115]

3. **Non-Resettable Hour Meter**

A non-resettable hour meter shall be installed and operated on Generator #3. [40 CFR §60.4209(a)]

4. Annual Time Limit for Maintenance and Testing

- a. Generator #3 shall be limited to 100 hours/year for maintenance checks and readiness testing, emergency demand response, and periods of voltage or frequency deviation from standards. Up to 50 hours/year of the 100 hours/year may be used in non-emergency situations (this does not include peak shaving, non-emergency demand response, or to generate income for a facility by providing power to an electric grid or otherwise supply power as part of a financial arrangement with another entity unless the conditions in §60.4211(f)(3)(i) are met). These limits are based on a calendar year. Compliance shall be demonstrated by a written log of all generator operating hours. [40 CFR §60.4211(f) and 06-096 CMR 115]
- b. SMHC-Biddeford shall keep records that include maintenance conducted on Generator #3 and the hours of operation of the engine recorded through the non-resettable hour meter. Documentation shall include the hours spent for emergency operation, including what classified the operation as emergency and how many hours spent for non-emergency. If Generator #3 is operated during a period of demand response or deviation from standard voltage or frequency, or to supply power during a non-emergency situation as part of a financial arrangement with another entity as specified in §60.4211(f)(3)(i), SMHC-Biddeford shall keep records of the notification of the emergency situation, and the date, start time, and end time of generator operation for these purposes.

5. Operation and Maintenance

Generator #3 shall be operated and maintained according to the manufacturer's emission-related written instructions or procedures developed by SMHC-Biddeford that are approved by the engine manufacturer. SMHC-Biddeford may only change those emission-related settings that are permitted by the manufacturer. [40 CFR §60.4211(a)]

6. Annual Reporting For Demand Response Availability Over 15 Hours Per Year (for generators greater than 100 brake hp)

If Generator #3 operates or is contractually obligated to be available for more than 15 hours per calendar year in a demand response program, during a period of deviation from standard voltage or frequency, or supplying power during a non-emergency situation as part of a financial arrangement with another entity as specified in §60.4211(f)(3)(i), SMHC-Biddeford shall submit an annual report containing the information in §60.4214(d)(1)(i) through (vii). The first annual report must cover the calendar year 2015 and must be submitted no later than March 31, 2016. Subsequent annual reports for each calendar year must be submitted no later than March 31 of the following calendar year. The annual report must be submitted electronically using the Compliance and Emissions Data Reporting Interface (CEDRI) that is accessed through EPA's Central Data

Southern Maine Health Care  
York County  
Biddeford, Maine  
A-006-71-P-R/M (SM)

24

Departmental  
Findings of Fact and Order  
Air Emission License  
Renewal/Amendment

Exchange (CDX) ([www.epa.gov/cdx](http://www.epa.gov/cdx)). However, if the reporting form is not available in CEDRI at the time that the report is due, the written report must be submitted to the following address:

Director, Office of Ecosystem Protection  
U.S. Environmental Protection Agency  
5 Post Office Square, Suite 100  
Boston, MA 02109-3912

[40 CFR §60.4214(d)]

- (19) SMHC-Biddeford shall notify the Department within 48 hours and submit a report to the Department on a quarterly basis if a malfunction or breakdown in any component causes a violation of any emission standard (38 M.R.S.A. §605).

DONE AND DATED IN AUGUSTA, MAINE THIS 18 DAY OF December, 2014.

DEPARTMENT OF ENVIRONMENTAL PROTECTION

BY: Marc Allen Robert Corne for  
PATRICIA W. AHO, COMMISSIONER

**The term of this license shall be ten (10) years from the signature date above.**

[Note: If a complete renewal application, as determined by the Department, is submitted prior to expiration of this license, then pursuant to Title 5 MRSA §10002, all terms and conditions of the license shall remain in effect until the Department takes final action on the renewal of the license.]

PLEASE NOTE ATTACHED SHEET FOR GUIDANCE ON APPEAL PROCEDURES

Date of initial receipt of application: 10/9/2014

Date of application acceptance: 10/10/2014

Date filed with the Board of Environmental Protection:

This Order prepared by Allison M. Hazard, Bureau of Air Quality.

