



STATE OF MAINE
DEPARTMENT OF ENVIRONMENTAL PROTECTION

PAUL R. LEPAGE
GOVERNOR

PATRICIA W. AHO
COMMISSIONER

**Waterville Public Schools
Kennebec County
Waterville, Maine
A-113-71-H-R**

**Departmental
Findings of Fact and Order
Air Emission License
Renewal**

After review of the air emissions license renewal application, staff investigation reports and other documents in the applicant's file in the Bureau of Air Quality, pursuant to 38 M.R.S.A., §344 and §590, the Department finds the following facts:

I. REGISTRATION

A. Introduction

Waterville Public Schools has applied to renew their Air Emission License permitting the operation of emission sources associated with their educational facility.

The equipment addressed in this license is located on the school campus at 1 Brooklyn Avenue in Waterville, Maine.

B. Emission Equipment

The following equipment is addressed in this air emission license:

Boilers

Equipment	Maximum Capacity (MMBTU/hr)	Maximum Firing Rate	Fuel Type	Install Date	Stack #
Boiler #1	4.6	33.0 gal/hr	#2 fuel oil, ASTM D396	2011	1
Boiler #2	5.1	626 lb/hr	Wood Pellets, 5% Moisture	2011	2
Boiler #3	4.3	30.5 gal/hr	#2 fuel oil, ASTM D396	1999	3

C. Application Classification

The application for Waterville Public Schools does not include the licensing of increased emissions or the installation of new or modified equipment. Therefore, the license is considered to be a renewal of currently licensed emission units only and has been processed through *Major and Minor Source Air Emission License Regulations*, 06-096 CMR 115 (as amended).

AUGUSTA
17 STATE HOUSE STATION
AUGUSTA, MAINE 04333-0017
(207) 287-7688 FAX: (207) 287-7826
RAY BLDG., HOSPITAL ST.

BANGOR
106 HOGAN ROAD, SUITE 6
BANGOR, MAINE 04401
(207) 941-4570 FAX: (207) 941-4584

PORTLAND
312 CANCO ROAD
PORTLAND, MAINE 04103
(207) 822-6300 FAX: (207) 822-6303

PRESQUE ISLE
1235 CENTRAL DRIVE, SKYWAY PARK
PRESQUE ISLE, MAINE 04679-2094
(207) 764-0477 FAX: (207) 760-3143

II. BEST PRACTICAL TREATMENT (BPT)

A. Introduction

In order to receive a license, the applicant must control emissions from each unit to a level considered by the Department to represent Best Practical Treatment (BPT), as defined in *Definitions Regulation*, 06-096 CMR 100 (as amended). Separate control requirement categories exist for new and existing equipment as well as for those sources located in designated non-attainment areas.

BPT for existing emissions equipment means that method which controls or reduces emissions to the lowest possible level considering:

- the existing state of technology;
- the effectiveness of available alternatives for reducing emissions from the source being considered; and
- the economic feasibility for the type of establishment involved.

B. Oil-Fired Boilers (Boilers #1 and #3)

Waterville Public Schools operates two oil-fired boilers to provide heat and hot water to their educational facility. Boilers #1 and #3 fire ASTM D396 compliant #2 fuel oil (maximum sulfur of 0.5%) and are rated at 4.6 and 4.3 MMBTU/hour, respectively. Boilers #1 and #3 were manufactured in 2011 and 1999 and exhaust through stacks at heights of 50 feet (Stack #1) and 25 feet (Stack #3) above local ground level, respectively.

Boilers #1 and #3 provide the balance of the heating load that Boiler #2 does not cover.

Due to their size, Boilers #1 and #3 are not subject to the New Source Performance Standards (NSPS) 40 CFR Part 60, Subpart Dc, *Standards of Performance for Small Industrial-Commercial-Institutional Steam Generating Units*, for units greater than 10 MMBTU/hour manufactured after June 9, 1989.

1. BPT Findings

The BPT emission limits for Boilers #1 and #3 were based on the following:

PM/PM ₁₀	0.08 lb/MMBTU, previous BACT determination
SO ₂	0.5 lb/MMBTU, firing ASTM D396 #2 fuel oil (0.5% S)
NO _x	20 lb/1000 gal, AP-42 Table 1.3-1, dated 5/10

CO 5 lb/1000 gal, AP-42, Table 1.3-1, dated 5/10
VOC 0.34 lb/1000 gal, AP-42, Table 1.3-3, dated 5/10
Opacity Based on 06-096 CMR 101, Visible Emission Regulation: visible emissions from Stacks #1 and #3 shall each not exceed 20% on a six-minute block average basis, except for no more than one six-minute block average in a three-hour period.

The pound/hour limits for Boiler #1 and #3 are as follows:

Equipment	PM (lb/hr)	PM ₁₀ (lb/hr)	SO ₂ (lb/hr)	NO _x (lb/hr)	CO (lb/hr)	VOC (lb/hr)
Boiler #1	0.4	0.4	2.3	0.7	0.2	0.1
Boiler #3	0.3	0.3	2.1	0.6	0.2	0.1

For Boilers #1 and #3, Waterville Public Schools shall be limited to a total of 70,000 gallons/year of ASTM D396 compliant #2 fuel oil, on a calendar year basis.

Until December 31, 2015, the fuel oil fired in Boiler 1 shall be ASTM D396 compliant #2 fuel oil (maximum sulfur content of 0.5% by weight). Per 38 MRSA §603-A(2)(A)(3), beginning January 1, 2016, the facility shall fire #2 fuel oil with a maximum sulfur content limit of 0.005% by weight (50 ppm), and beginning January 1, 2018, the facility shall fire #2 fuel oil with a maximum sulfur content limit of 0.0015% by weight (15 ppm).

Periodic Monitoring

Periodic monitoring for Boilers #1 and #3 shall include recordkeeping to document fuel use both on a monthly and calendar year basis. Documentation shall include the type and amount of fuel used.

C. Wood Pellet Fired Boiler (Boiler #2)

Waterville Public Schools operates one wood pellet fired boiler to provide heat and hot water to their educational facility. Boiler #2 is rated at 5.1 MMBtu/hr and fires wood pellets at 5% moisture. Boiler #2 was manufactured in 2011 and exhausts through Stack #2 at a height of 58 feet above local ground level.

Boiler #2 provides approximately 60-70% of the design maximum heating load for the building.

The boiler system includes the boiler and a material handling system. The wood pellets will be conveyed from the receiving bin to an inclined conveyor and then

to another conveyor to bring the pellets to the surge hopper. They will then travel through the fuel airlock and to Boiler #2. Boiler #2 is a two pass unit with a refractory lined furnace sitting under an open bottom firebox boiler. The combustion air system consists of over-fire air and a partitioned under-grate air system. Particulate emissions control consists of a multi-clone fly-ash collector with rotary ash valve. The exhaust stream is pulled through the multi-clone by an induced draft fan. The collected particles will drop into the ash collection barrel.

Due to its size, Boiler #2 is not subject to the New Source Performance Standards (NSPS) 40 CFR Part 60, Subpart Dc, *Standards of Performance for Small Industrial-Commercial-Institutional Steam Generating Units*, for units greater than 10 MMBTU/hour manufactured after June 9, 1989.

1. BPT Findings

The BPT emission limits for Boiler #2 were based on the following:

PM/PM₁₀ 0.23 lb/MMBTU, previous BACT determination
SO₂ 0.025 lb/MMBTU, AP-42 Table 1.6-2, dated 9/03
NO_x 0.49 lb/MMBTU, AP-42 Table 1.6-2, dated 9/03
CO 0.6 lb/MMBTU, AP-42 Table 1.6-2, dated 9/03
VOC 0.017 lb/MMBTU, AP-42 Table 1.6-3, dated 9/03
Opacity Based on 06-096 CMR 101, Visible Emission Regulation: visible emissions from Stack #1 shall not exceed 20% on a six-minute block average basis, except for no more than two six-minute block averages in a three-hour period.

The pound/hour limits for Boiler #2 are as follows:

Equipment	PM (lb/hr)	PM ₁₀ (lb/hr)	SO ₂ (lb/hr)	NO _x (lb/hr)	CO (lb/hr)	VOC (lb/hr)
Boiler #2	1.2	1.2	0.1	2.5	3.1	0.1

Boiler #2 shall be limited to 1200 tons/year of wood pellets at 5% moisture content with a heat content of 8150 Btu/lb (or equivalent), on a calendar year basis.

Periodic Monitoring

Periodic monitoring for Boiler #2 shall include recordkeeping to document fuel use both on a monthly and calendar year basis. Compliance may be based on either delivery records, including receipts of wood pellet deliveries

and a record of deliveries each month to represent the fuel consumed for the month, or actual fuel metering data.

D. 40 CFR Part 63 Subpart JJJJJ

Boilers #1, #2 and #3 may be subject to the *National Emission Standards for Hazardous Air Pollutants for Industrial, Commercial, and Institutional Boilers Area Sources* (40 CFR Part 63 Subpart JJJJJ).

For informational purposes, a summary of the currently applicable federal 40 CFR Part 63 Subpart JJJJJ requirements is listed below. At this time, the Maine Department of Environmental Protection has not taken delegation of this area source MACT (Maximum Achievable Control Technology) rule promulgated by USEPA, however Waterville Public Schools is still subject to the requirements. Notification forms and additional rule information can be found on the following website: <http://www.epa.gov/ttn/atw/boiler/boilerpg.html>.

a. Compliance Dates, Notifications, and Work Practice Requirements

i. Initial Notification of Compliance

An Initial Notification submittal to EPA was due on September 17, 2011 for existing sources. The Initial Notification for new sources is due within 120 days after the source becomes subject to the standard. [40 CFR Part 63.11225(a)(2)]

ii. Boiler Tune-Up Program – Initial and Biennial

(a) A boiler tune-up program shall be implemented to include the tune-up of the existing boilers by March 21, 2012. [40 CFR Part 63.11196(a)(1)] The tune-up program shall be implemented upon startup of the new boilers. [40 CFR Part 63.11196(c)]

(b) The boiler tune-up program, conducted to demonstrate continuous compliance, shall be performed as specified below:

1. As applicable, inspect the burner, and clean or replace any component of the burner as necessary. Delay of the burner inspection until the next scheduled shutdown is permitted; however, the burner must be inspected at least once every 36 months. [40 CFR Part 63.11223(b)(1)]
2. Inspect the flame pattern, as applicable, and adjust the burner as necessary to optimize the flame pattern, consistent with the manufacturer's specifications. [40 CFR Part 63.11223(b)(2)]

3. Inspect the system controlling the air-to-fuel ratio, as applicable, and ensure it is correctly calibrated and functioning properly. [40 CFR Part 63.11223(b)(3)]
 4. Optimize total emissions of CO, consistent with manufacturer's specifications. [40 CFR Part 63.11223(b)(4)]
 5. Measure the concentration in the effluent stream of CO in parts per million (ppm), by volume, and oxygen in volume percent, before and after adjustments are made. [40 CFR Part 63.11223(b)(5)]
 6. If a unit is not operating on the required date for a tune-up, the tune-up must be conducted within one week of start-up. [40 CFR Part 63.11223(b)(7)]
- (c) A Notification of Compliance Status shall be submitted to EPA no later than 120 days after conducting the initial boiler tune-up. [40 CFR Part 63.11225(a)(4) and 40 CFR Part 63.11214(b)]
- (d) Waterville Public Schools shall implement a biennial boiler tune-up program after the initial tune-up and initial compliance report has been submitted.
1. Each biennial tune-up shall be conducted no more than 25 months after the previous tune-up. [40 CFR Part 63.11223(a)]
 2. The biennial report shall be maintained onsite and submitted to EPA, if requested. The report shall contain the concentration of CO in the effluent stream (ppmv) and oxygen in volume percent, measured before and after the boiler tune-up, a description of any corrective actions taken as part of the tune-up of the boiler, and the type and amount of fuel used over the 12 months prior to the biennial tune-up of the boiler. [40 CFR Part 63.11223(b)(6)] The biennial compliance report shall also include the company name and address; a compliance statement signed by a responsible official certifying truth, accuracy, and completeness; and a description of any deviations and corrective actions. [40 CFR Part 63.11225(b)]

b. Recordkeeping

Records shall be maintained consistent with the requirements of 40 CFR Part 63 Subpart JJJJJ including the following [40 CFR Part 63.11225(c)]: copies of notifications and reports with supporting compliance documentation; identification of each boiler, the date of tune-up, procedures followed for tune-up, and the manufacturer's specifications to which the boiler was tuned; documentation of fuel type(s) used monthly

by each boiler; the occurrence and duration of each malfunction of the boiler; and actions taken during periods of malfunction to minimize emissions and actions taken to restore the malfunctioning boiler to its usual manner of operation. Records shall be in a form suitable and readily available for expeditious review.

E. Fugitive and General Process Emissions

Visible emissions from any fugitive emissions source (including the delivery and handling of wood pellets) shall not exceed an opacity of 20%, except for no more than five minutes in any 1-hour period. Compliance shall be determined by an aggregate of the individual fifteen-second opacity observations which exceed 20% in any one hour.

Visible emissions from any general process source shall not exceed an opacity of 20% on a six-minute block average basis, except for no more than one six-minute block average in a one-hour period.

F. Annual Emissions

1. Total Annual Emissions

Waterville Public Schools shall be restricted to the following annual emissions, on a calendar year basis:

Total Licensed Annual Emissions for the Facility
Tons/year
(used to calculate the annual license fee)

Equipment	PM	PM ₁₀	SO ₂	NO _x	CO	VOC
Boilers #1 and #3 (oil)	0.39	0.39	2.45	0.70	0.18	0.01
Boiler #2 (wood pellets)	2.25	2.25	0.24	4.79	5.87	0.17
Total TPY	2.6	2.6	2.7	5.5	6.1	0.2

The tons per year limits were calculated based on a 70,000 gallon per year limit of ASTM D396 compliant #2 fuel oil and a 1,200 tons per year limit of wood pellets with 5% moisture and 8150 Btu/lb heat content (or equivalent).

2. Greenhouse Gases

Greenhouse gases are considered regulated pollutants as of January 2, 2011, through 'Tailoring' revisions made to EPA's *Approval and Promulgation of Implementation Plans*, 40 CFR Part 52, Subpart A, §52.21 Prevention of

Significant Deterioration of Air Quality rule. Greenhouse gases, as defined in 06-096 CMR 100 (as amended), are the aggregate group of the following gases: Carbon dioxide, nitrous oxide, methane, hydrofluorocarbons, perfluorocarbons, and sulfur hexafluoride. For licensing purposes, greenhouse gases (GHG) are calculated and reported as carbon dioxide equivalents (CO₂e).

Based on Waterville Public School's fuel use limits, the worst case emission factors from AP-42, IPCC (Intergovernmental Panel on Climate Change), and *Mandatory Greenhouse Gas Reporting*, 40 CFR Part 98, and the global warming potentials contained in 40 CFR Part 98, Waterville Public School is below the major source threshold of 100,000 tons of CO₂e per year. Therefore, no additional licensing requirements are needed to address GHG emissions at this time.

III. AMBIENT AIR QUALITY ANALYSIS

According to 06-096 CMR 115, the level of air quality analyses required for a renewal source shall be determined on a case-by case basis. Modeling is not required for a renewal if the total emissions of any pollutant released do not exceed the following and there are no extenuating circumstances:

Pollutant	Tons/Year
PM	25
PM ₁₀	25
SO ₂	50
NO _x	100
CO	250

Based on the total facility licensed emissions, Waterville Public School is below the emissions level required for modeling.

ORDER

Based on the above Findings and subject to conditions listed below the Department concludes that the emissions from this source:

- will receive Best Practical Treatment (BPT) / Best Available Control Technology (BACT),
- will not violate applicable emission standards,
- will not violate applicable ambient air quality standards in conjunction with emissions from other sources.

The Department hereby grants Air Emission License A-113-71-H-R, subject to the following conditions.

Severability. The invalidity or unenforceability of any provision, or part thereof, of this License shall not affect the remainder of the provision or any other provisions. This License shall be construed and enforced in all respects as if such invalid or unenforceable provision or part thereof had been omitted.

STANDARD CONDITIONS

- (1) Employees and authorized representatives of the Department shall be allowed access to the licensee's premises during business hours, or any time during which any emissions units are in operation, and at such other times as the Department deems necessary for the purpose of performing tests, collecting samples, conducting inspections, or examining and copying records relating to emissions (38 M.R.S.A. §347-C).
- (2) The licensee shall acquire a new or amended air emission license prior to commencing construction of a modification, unless specifically provided for in Chapter 115. [06-096 CMR 115]
- (3) Approval to construct shall become invalid if the source has not commenced construction within eighteen months after receipt of such approval or if construction is discontinued for a period of eighteen months or more. The Department may extend this time period upon a satisfactory showing that an extension is justified, but may condition such extension upon a review of either the control technology analysis or the ambient air quality standards analysis, or both. [06-096 CMR 115]
- (4) The licensee shall establish and maintain a continuing program of best management practices for suppression of fugitive particulate matter during any period of construction, reconstruction, or operation which may result in fugitive dust, and shall submit a description of the program to the Department upon request. [06-096 CMR 115]
- (5) The licensee shall pay the annual air emission license fee to the Department, calculated pursuant to Title 38 M.R.S.A. §353-A. [06-096 CMR 115]
- (6) The license does not convey any property rights of any sort, or any exclusive privilege. [06-096 CMR 115]

- (7) The licensee shall maintain and operate all emission units and air pollution systems required by the air emission license in a manner consistent with good air pollution control practice for minimizing emissions. [06-096 CMR 115]
- (8) The licensee shall maintain sufficient records to accurately document compliance with emission standards and license conditions and shall maintain such records for a minimum of six years. The records shall be submitted to the Department upon written request. [06-096 CMR 115]
- (9) The licensee shall comply with all terms and conditions of the air emission license. The filing of an appeal by the licensee, the notification of planned changes or anticipated noncompliance by the licensee, or the filing of an application by the licensee for a renewal of a license or amendment shall not stay any condition of the license. [06-096 CMR 115]
- (10) The licensee may not use as a defense in an enforcement action that the disruption, cessation, or reduction of licensed operations would have been necessary in order to maintain compliance with the conditions of the air emission license. [06-096 CMR 115]
- (11) In accordance with the Department's air emission compliance test protocol and 40 CFR Part 60 or other method approved or required by the Department, the licensee shall:
 - A. perform stack testing to demonstrate compliance with the applicable emission standards under circumstances representative of the facility's normal process and operating conditions:
 1. within sixty calendar days of receipt of a notification to test from the Department or USEPA, if visible emissions, equipment operating parameters, staff inspection, air monitoring or other cause indicate to the Department that equipment may be operating out of compliance with emission standards or license conditions; or
 2. pursuant to any other requirement of this license to perform stack testing.
 - B. install or make provisions to install test ports that meet the criteria of 40 CFR Part 60, Appendix A, and test platforms, if necessary, and other accommodations necessary to allow emission testing; and
 - C. submit a written report to the Department within thirty days from date of test completion.
[06-096 CMR 115]

- (12) If the results of a stack test performed under circumstances representative of the facility's normal process and operating conditions indicate emissions in excess of the applicable standards, then:
- A. within thirty days following receipt of such test results, the licensee shall re-test the non-complying emission source under circumstances representative of the facility's normal process and operating conditions and in accordance with the Department's air emission compliance test protocol and 40 CFR Part 60 or other method approved or required by the Department; and
 - B. the days of violation shall be presumed to include the date of stack test and each and every day of operation thereafter until compliance is demonstrated under normal and representative process and operating conditions, except to the extent that the facility can prove to the satisfaction of the Department that there were intervening days during which no violation occurred or that the violation was not continuing in nature; and
 - C. the licensee may, upon the approval of the Department following the successful demonstration of compliance at alternative load conditions, operate under such alternative load conditions on an interim basis prior to a demonstration of compliance under normal and representative process and operating conditions.
- [06-096 CMR 115]
- (13) Notwithstanding any other provisions in the State Implementation Plan approved by the USEPA or Section 114(a) of the CAA, any credible evidence may be used for the purpose of establishing whether a person has violated or is in violation of any statute, regulation, or Part 70 license requirement. [06-096 CMR 115]
- (14) The licensee shall maintain records of malfunctions, failures, downtime, and any other similar change in operation of air pollution control systems or the emissions unit itself that would affect emission and that is not consistent with the terms and conditions of the air emission license. The licensee shall notify the Department within two days or the next state working day, whichever is later, of such occasions where such changes result in an increase of emissions. The licensee shall report all excess emissions in the units of the applicable emission limitation. [06-096 CMR 115]
- (15) Upon written request from the Department, the licensee shall establish and maintain such records, make such reports, install, use and maintain such monitoring equipment, sample such emissions (in accordance with such methods, at such locations, at such intervals, and in such a manner as the Department shall

prescribe), and provide other information as the Department may reasonably require to determine the licensee's compliance status. [06-096 CMR 115]

SPECIFIC CONDITIONS

(16) Boilers #1 and #3

A. Fuels

1. Total fuel use for Boilers #1 and #3 combined shall not exceed 70,000 gallons/year of ASTM D396 compliant #2 fuel oil, on a calendar year basis. [06-096 CMR 115, BPT]
2. Until December 31, 2015, the fuel fired in the boilers shall be ASTM D396 compliant #2 fuel oil with a maximum sulfur content of 0.5% by weight. [06-096 CMR 115, BPT]
3. Beginning January 1, 2016, the fuel fired in the boilers shall be #2 fuel oil with a maximum sulfur content limit of 0.005% by weight (50 ppm). [38 MRSA §603-A(2)(A)(3)]
4. Beginning January 1, 2018, the fuel fired in the boilers shall be #2 fuel oil with a maximum sulfur content limit of 0.0015% by weight (15 ppm). [38 MRSA §603-A(2)(A)(3)]
5. Compliance shall be demonstrated by fuel records from the supplier showing the quantity, type, and the percent sulfur of the fuel delivered (if applicable). Records of annual fuel oil use shall be kept on a monthly and calendar year basis. [06-096 CMR 115, BPT]

B. Emissions from Boilers #1 and #3 shall not exceed the following:

Equipment	Pollutant	lb/MMBTU	Origin and Authority
Boilers #1 and #3	PM	0.08	06-096 CMR 115, BACT

C. Emissions from Boilers #1 and #3 shall not exceed the following [06-096 CMR 115, BPT]:

Equipment	PM (lb/hr)	PM ₁₀ (lb/hr)	SO ₂ (lb/hr)	NO _x (lb/hr)	CO (lb/hr)	VOC (lb/hr)
Boiler #1	0.4	0.4	2.3	0.7	0.2	0.1
Boiler #3	0.3	0.3	2.1	0.6	0.2	0.1

D. Visible emissions from Stacks #1 and #3, servicing Boilers #1 and #3 respectively, shall each not exceed 20% on a six-minute block average basis, except for no more than one six-minute block average in a three-hour period. [06-096 CMR 101]

(17) **Boiler #2**

A. Boiler #2 shall be limited to 1200 tons/year of wood pellets at 5% moisture content with a heat content of 8150 Btu/lb (or equivalent), on a calendar year basis. Compliance may be based on either delivery records, including receipts of wood pellet deliveries and a tally of deliveries each month to represent the fuel consumed for the month, or actual fuel metering data. Records of annual fuel use shall be kept on a monthly and calendar year basis. [06-096 CMR 115, BACT]

B. Waterville Public Schools shall operate a multi-cyclone on Boiler #2 for particulate matter control. Waterville Public Schools shall maintain a log detailing all routine and non-routine maintenance on the multi-clone. The log shall include the date and maintenance description. [06-096 CMR 115, BPT]

C. Emissions from Boiler #2 shall not exceed the following:

Equipment	Pollutant	lb/MMBtu	Origin and Authority
Boiler #2	PM	0.23	06-096 CMR 103, Section 2(B)(4)(a)

D. Emissions from Boiler #2 shall not exceed the following [06-096 CMR 115, BPT]:

Equipment	PM (lb/hr)	PM ₁₀ (lb/hr)	SO ₂ (lb/hr)	NO _x (lb/hr)	CO (lb/hr)	VOC (lb/hr)
Boiler #2	1.2	1.2	0.1	2.5	3.1	0.1

E. Visible emissions from Stack #2, servicing Boiler #2, shall not exceed 20% on a six-minute block average basis, except for no more than two six-minute block averages in a continuous three-hour period. [06-096 CMR 101]

F. Ash from Boiler #2 shall be disposed of in accordance with the Bureau of Remediation and Waste Management (BRWM). Ash shall be sufficiently

conditioned with water or transported in covered containers so as to prevent fugitive emissions. [06-096 CMR 115, BPT]

(18) **Fugitive Emissions**

Visible emissions from any fugitive emissions source (including the delivery and handling of wood pellets) shall not exceed an opacity of 20%, except for no more than five minutes in any 1-hour period. Compliance shall be determined by an aggregate of the individual fifteen-second opacity observations which exceed 20% in any one hour. [06-096 CMR 101]

(19) **General Process Sources**

Visible emissions from any general process source shall not exceed an opacity of 20% on a six-minute block average basis, except for no more than one six-minute block average in a one-hour period. [06-096 CMR 101]

(20) Waterville Public Schools shall notify the Department within 48 hours and submit a report to the Department on a quarterly basis if a malfunction or breakdown in any component causes a violation of any emission standard (38 M.R.S.A. §605).

DONE AND DATED IN AUGUSTA, MAINE THIS 20 DAY OF December, 2012.

DEPARTMENT OF ENVIRONMENTAL PROTECTION

BY: Marc Allen Robert Cone for
PATRICIA W. AHO, COMMISSIONER

The term of this license shall be ten (10) years from the signature date above.

[Note: If a complete renewal application, as determined by the Department, is submitted prior to expiration, then pursuant to Title 5 MRSA §10002, all terms and conditions of the license shall remain in effect until the Department takes final action on the renewal of the license.]

PLEASE NOTE ATTACHED SHEET FOR GUIDANCE ON APPEAL PROCEDURES

Date of initial receipt of application: December 20, 2011

Date of application acceptance: December 27, 2011

Date filed with the Board of Environmental Protection:
This Order prepared by Kevin J Ostrowski, Bureau of Air Quality.

