


NOTES:

1. SPOIL GENERATED AND USED ON THE SAME DAY MAY BE TEMPORARILY STOCKPILED NEAR THE EXCAVATION UNDER DRY WEATHER CONDITIONS ONLY.
2. WHERE PRACTICABLE, INACTIVE SPOIL PILES WITH HIGH SILT OR CLAY CONTENT WILL BE LOCATED A MINIMUM OF 150 FEET FROM RESOURCES.
3. INSTALL SILT FENCE OR EROSION CONTROL MULCH IN THE SINGLE LAYER CONFIGURATION (DETAILS A AND B) AROUND ALL HIGH SILT AND CLAY CONTENT SPOIL PILES LOCATED GREATER THAN 150 FEET FROM RESOURCES.
4. INSTALL EROSION AND SEDIMENTATION CONTROLS PER THE MULTIPLE LAYER CONFIGURATIONS (DETAILS C AND D) IN ALL AREAS, INCLUDING TEMPORARY STOCKPILES, THAT ARE WITHIN 100 FEET OF RESOURCES WHERE THE SOIL HAS HIGH SILT OR CLAY CONTENT.
5. INACTIVE SPOIL PILES WILL BE MULCHED AT A RATE OF 3.5 TONS PER ACRE.

	CENTRAL MAINE POWER COMPANY
	EROSION AND SEDIMENTATION CONTROL FOR STRUCTURE INSTALLATION IN HIGH RISK AREAS