

## MacNeil, Jami

---

**From:** Noble, William T  
**Sent:** Monday, February 14, 2022 8:33 AM  
**To:** MacNeil, Jami  
**Subject:** Comment Revision: Sugarloaf West Mountain Expansion, Carrabassett Valley

**Follow Up Flag:** Follow up  
**Flag Status:** Completed

This is a revision to comment 10 of the geology review memo dated 2-11-22. Reference to low-permeability liner material in cross-section details on plan sheet C1.06 should be removed.

Basin siting standards in Chapter 7.1 of the stormwater BMPs indicate that an impermeable liner for underdrained soil filter basins not consist of “clay”, which suggests that other “low-permeability” earth materials would not be considered acceptable.

William T. Noble, L.G.  
Environmental Geology Unit  
Division of Land Licensing  
DEP Bureau of Land Resources  
(207) 215-1792  
[www.maine.gov/dep/](http://www.maine.gov/dep/)