

Underground Oil Storage Tank Alarm Console Monitoring Log



Facility Name			Registration #		
Console Make/Model					
Date	In Alarm? (Yes/No)	Alarm Description	Alarm Reported to	Date Reported	Your Name

Instructions: Regularly check the status of your facility's tank/piping alarm console (*recommended* weekly, but *at least* once every month). If it is operating normally, has no audible or visual indications of an alarm and the console test (if so equipped) is normal, record the date, mark *No* in the "In Alarm?" box and record your name in the "Your Name" box. If during your check of the console you find alarm conditions (example: an alarm light is lit, an alarm message is on the screen or the audible alarm is sounding, etc.), mark *Yes* in the "In Alarm?" box and fill in the rest of the required information on the form. All alarms other than "low fuel" <u>must</u> be reported to the DEP within 24 hours and investigated by a Maine Certified Underground Storage Tank Installer or Inspector.

Once filled-in, keep this form in the facility's records for three years