



STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE
04333-0016

JOHN ELIAS BALDACCI
GOVERNOR

DAVID A. COLE
COMMISSIONER

March 3, 2008
Subject: **Paris, Catch Basins**
State Pin No.: 013035.00
Amendment No. 1

Dear Sir/Ms:

Please make the following changes to the Bid Documents:

On Appendix A Sheet 2 of 4, (CB #1 & CB #2) **DELETE** 3' round Catch Basins and **REPLACE** with Square Catch Basins 2' inside diameter. Make these changes in pen and ink.

On Appendix A Sheets 2, 3 and 4 of 4, (CB#3- CB #12) **DELETE** 5' Diameter and **REPLACE** with 4 ft. Inside Diameter. Make these changes in pen and ink.

On Appendix A Sheet 2 of 4, (CB#3, CB #4 & CB #5) **DELETE** "Pipe Size 21" Plastic" and **REPLACE** with "Pipe Size 24"Plastic". Make these changes in pen and ink.

The following questions have been received:

Question: CB #1 & #2. Type "F" Catch Basins are 3 ft. square on outside not round.

Response: Yes, they should be square. See revisions to Appendix A provided earlier in this amendment.

Question: CB#2 to CB#12. Catch Basins are usually specified by inside diameter. Your diagrams are showing 5 ft. dia. Catch Basins other than #4, a 4 ft. dia. Basin (4'10" outside diameter) will be adequate. Is 5' dia. required for all?

Response: CB # 3-12 will be 4' inside diameter. See revisions to Appendix A provided earlier in this amendment.



PRINTED ON RECYCLED PAPER

Question: 21" HDPE Storm Drain not generally available.

Response: Pipe Size has been changed to 24". See revisions to Appendix A provided earlier in this amendment.

Consider these changes & information prior to submitting your bid on March 26, 2008.

Sincerely,

A handwritten signature in black ink that reads "Scott Bickford for". The signature is written in a cursive style.

Scott Bickford
Contracts & Specifications Engineer