



STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE
04333-0016

JOHN ELIAS BALDACCI
GOVERNOR

DAVID A. COLE
COMMISSIONER

April 29, 2010
Subject: **Lyman**
State Pin No: 016713.00
Amendment No. 1

Dear Sir/Ms:

The following question has been received:

Question: Project scope has specified concrete invert lining. Would the FRP system installed in Amherst Maine on PIN 15642 in 2009 be an acceptable alternate?

Response: No, The FRP system installed in Amherst will not be an acceptable alternative for this project.

Consider this information prior to submitting your bid on May 5, 2010.

Sincerely,

A handwritten signature in cursive script, appearing to read "S. Bickford".

FOR Scott Bickford
Contracts & Specifications Engineer



PRINTED ON RECYCLED PAPER