

PRE-BID MEETING

MAIN/ CEDAR STREET INTERSECTION IMPROVEMENTS PROJECT **MDOT PIN 15117.00**

MARCH 23, 2010
10:00 am @ Bangor City Hall

Response to Questions:

1. Does Contractor have to be MDOT approved/ Certified?

Ans. The prime contractor has to be approved/ certified by the MDOT.

2. Can contractor work at night?

Ans. The City typically does not allow for night work.

3. Can the contractor close Cedar Street during construction?

Ans. The contractor will have to submit a traffic control plan to be reviewed and approved by the City prior to construction.

4. Asbestos survey and possible removal?

Ans. The Contractor will conduct an asbestos survey on the building by a DEP certified inspector and this survey will be incidental to the building removal. If asbestos is found, the contractor will employ a DEP certified Asbestos Abatement Contractor for its removal and disposal. The Department will pay for the expenses incurred in the abatement of the asbestos as a change order as detailed in Standard Specification 109.7.5 – Force Account.