



STATE OF MAINE  
DEPARTMENT OF TRANSPORTATION  
16 STATE HOUSE STATION  
AUGUSTA, MAINE  
04333-0016

JOHN ELIAS BALDACCI  
GOVERNOR

DAVID A. COLE  
COMMISSIONER

August 24, 2009  
Subject: **Bangor Roof Replacement**  
PINS: N/A  
Location: Region 4

**Bid Amendment No. 1**

Dear Sir/Ms.:

The following questions have been received:

**Question:** Reference the Specifications on page 27, New Insulation. Please clarify are you asking for a total R value of R-20, Note: PIMA (Polyiso Insulation Manufacturers Assoc.) switch to LTTR (Long Term Thermal Resistance) in 2003, see the attached chart. So R-20 would be 2 layers of 1.7" ISO or are you asking for R-20 per layer i.e. 2 layers of 3.3" ISO?

**Response:** The total R value of the combined two layers of poly isocyanurate insulation shall be R-20 or greater.

**Question:** Is a bid bond required on this project?

**Response:** No

Consider this information prior to submitting your bid on August 26, 2009.

Sincerely,

FOR

Scott Bickford  
Contracts & Specifications Engineer



PRINTED ON RECYCLED PAPER